

**Fire Curtain Barriers**  
**Declaration of Performance**  
803626



- |                                    |   |
|------------------------------------|---|
| 1. System type identification code | Fire Protection Curtain, BSV-RS   |
| 2. Serial no.                      | Order- or itemnumber according to delivery order or documentation   |
| 3. Intended use                    | Fire/smoke compartmentation and on escape routes  |
| 4. Manufacturer                    | clauss markisen Projekt GmbH<br>Sindelfingerstr. 21<br>70771 Leinfelden-Echterdingen  |
| 5. Performance evaluation system   | 1   |
| 6. Harmonised standards            | EN 16034:2014<br>EN 13241:2003+A2:2016  |
| 7. Notified body                   | " The notified product certification body No. 1322 has carried out the determination of the product type on the basis of type testing (including samplin) the initial inspection of the manufacturing company and factory production control and the continous surveillance, assessment and evaluation of factory control, and has issued the certificate of constancy of performance of the system with certificate No. 1322-CPR-76655/04" |

8.Declared performance:

Essential characteristics	Performance class / value	Harmonised technical specification
8.1 Fire resistance*	E30;E60;E90;E120;E180;	EN 16034:2014
8.2 Smoke protection	Sa	
8.3 Self-closing	C	
8.4 Ability to release	fulfilled	
8.5 Durability of ability to release	NPD	
8.6 Durability of self-closing:		
- against degradation (continuous function test)	2	EN 13241:2016-12
- against ageing (corrosion)	fulfilled	
8.7 Safe opening	achieved	
8.8 Self closing	achieved	
8.9 Protection against crushing/shearing	achieved	
8.10 Protection against tripping	achieved	

\*"The product-specific fire resistance depends on the system design and, like the serial No., is specified and marked to order. The order-related data is a supplement to this declaration of performance."

9. The declared performance characteristics / classes according to point 8 are fulfilled by the system according to point 1. The manufacturer is solely responsible for drawing up the declaration of performance in accordance with point 4.

Uwe Neudeck  
Managing Director

Leinfelden Echterdingen  
2. Mai. 2022

**CM** clauss markisen  
Projekt GmbH  
Sindelfinger Straße 21 • Tel. 0711. 489995-0  
70771 Leinfelden-Echterdingen (Musberg)  
www.clauss-markisen.de