Fire Curtain Barriers

Declaration of Performance 805126



1. System type identification code

2. Serial no.

3. Intended use

4. Manufacturer

Fire Protection Curtain, BSV-EI

Order- or itemnumber according to delivery order or documentation

Fire/smoke compartmentation and on escape routes

clauss markisen Projekt GmbH Sindelfingerstr. 21 70771 Leinfelden-Echterdingen

5. Performance evaluation system

6. Harmonised standards

7. Notified body

EN 16034:2014 EN 13241:2003+A2:2016

1

" The notified product certification body No. 1322 has carried out the determination of the product type on the basis of type testing (including samplin) the initial inspection of the manufactoring company and factory production control and the continous surveillance, assessment and evaluation of factory control, and has issued the certificate of constancy of performance of the system with certificate No. 1322-CPR-76655/03"

8.Declared performance:

Essential characteristics	Performance class / value	Harmonised technical specification
8.1 Fire resistance*	El215; El220; El230	EN 16034:2014
8.2 Smoke protection	NPD	
8.3 Self-closing	С	
8.4 Ability to release	fullfilled	
8.5 Durability of ability to release	NPD	
3.6 Durability of self-closing:		
- against degradation (continous function test)	NPD	
- against ageing (corrosion)	fullfilled	
8.7 Safe opening	achieved	EN 13241:2016-12
8.8 Self closing	achieved	
8.9 Protection against crushing/shearing	achieved	
8.10 Protection against tripping	achieved	

*"The product-specific fire resistance depends on the system design and, like the serial No., is specified and markerd to order. The order-related data is a supplement to this declaration of performance."

9. The declared performance characteristics / classes according to point 8 are fullfilled by the system according to point 1. The manufacturer is soley responsible for drawing up the declaration of performance in accordance with point 4.

U. Na

Leinfelden Echterdingen 2. Mai. 2022 Uwe Neudeck Managing Director



Sindelfinger Straße 21 · Tel. 0711. 489995-0 70771 Leinfelden-Echterdingen (Musberg) www.clauss-markisen.de